

Disinfectant	Date	HighestRAA	Unit	Range	MRDL	MRDLG	Typical Source			
CHLORINE	2025	1	ppm	0.54 – 1	4	4	Water additive used to control microbes			
Lead and Copper	Period	90 th Percentile: 90% of your water utility levels were less than		Range of Sampled Results (low – high)	Unit	AL	Sites Over AL	Typical Source		
COPPER, FREE	2021 - 2024	0.105		0.026 – 0.15	ppm	1.3	0	Corrosion of household plumbing systems; Erosion of natural deposits; Leaching from wood preservatives		
LEAD	2021 - 2024	2.11		1.53 – 21.6	ppb	15	1	Corrosion of household plumbing systems; Erosion of natural deposits		
Disinfection Byproducts		Sample Point		Period	Highest LRAA	Range	Unit	MCL	MCLG	Typical Source
TOTAL HALOACETIC ACIDS (HAA5)		2 MAPLE ST (7/31/17)		2024 - 2025	10	9.8	ppb	60	0	By-product of drinking water disinfection
TOTAL HALOACETIC ACIDS (HAA5)		827 MARKET ST		2024 - 2025	9	8.88	ppb	60	0	By-product of drinking water disinfection
TTHM		2 MAPLE ST (7/31/17)		2024 - 2025	15	14.9	ppb	80	0	By-product of drinking water chlorination
TTHM		827 MARKET ST		2024 - 2025	23	22.6	ppb	80	0	By-product of drinking water chlorination
Regulated Contaminants		Collection Date	Highest Value	Range	Unit	MCL	MCLG	Typical Source		
BARIUM		4/4/2023	0.047	0.047	ppm	2	2	Discharge of drilling wastes; Discharge from metal refineries; Erosion of natural deposits		
FLUORIDE		4/4/2023	0.136	0.136	ppm	4	4	Erosion of natural deposits; Water additive which promotes strong teeth; Discharge from fertilizer and aluminum factories		
NITRATE		5/12/2025	3.51	3.51	ppm	10	10	Runoff from fertilizer use; Leaching from septic tanks, sewage; Erosion of natural deposits		
NITRATE-NITRITE		4/1/2024	2.97	2.97	ppm	10	10	Runoff from fertilizer use; Leaching from septic tanks, sewage; Erosion of natural deposits		
Radiological Contaminants		Collection Date	Highest Value	Range	Unit	MCL	MCLG	Typical Source		
GROSS ALPHA, EXCL. RADON & U		7/7/2019	2	2	pCi/L	15	0	Erosion of natural deposits		
RADIUM-228		7/7/2019	0.35	0.35	pCi/L	5	0			
Violations										
During the period covered by this report we had the below noted violations.										
Violation Period		Analyte			Violation Type			Violation Explanation		
6/30/2025-7/9/2025		CONSUMER CONFIDENCE RULE			CCR ADEQUACY/AVAILABILITY/CONTENT			Inadequate Consumer Confidence Report (CCR) or failure to deliver a CCR Certification form to the state on time.		
Deficiencies										
Unresolved significant deficiencies that were identified during a survey done on the water system are shown below.										
Date Identified	Facility			Code	Activity	Due Date	Description			
No deficiencies during this period.										